
Reabilitare tablou electric actionare semiautomata cazane apa calda, caldura si abur

I.D.: 64071514

Data publicarii	10.12.21	Coduri CPV	50000000-5
-----------------	----------	------------	------------

Pretul estimativ: 18.000,00 RON - 18.000,00 RON

Descriere: PREZENTA TINE LOC DE COMANDA FERMA Materiale necesare in vederea reabilitarii:
Intrerupator USOL 4P- 125A; Intrerupator USOL 4P- 50A; Intrerupator USOL 4P- 16; Siguranta bipolara- 16A; Siguranta bipolara- 10A; Distribuitor trifazic 160A; Cutie metalica 1000x600; Contactoare fonta 16A; Protectie motoare: 6.3-10A, 2.5-4A, 1.6-2,5A,1-1,6A; Selector 0-1; Contacte selector NO; Lampi tablouri: rosu, verde si galben; Cleme SIR- 4mm; Pini 1,5; Pini 2,5; Presetupa PG-18; Presetupa PG-21; Conductor MYF; Canal cablu: 60x40, 40x40, 20x40; Sina omega.
