

---

## Servicii reparatii generator la salupa Opal SAR

I.D.: 15989841

---

Data publicarii	09.11.16	Coduri CPV	50532300-6
-----------------	----------	------------	------------

---

Termenul limita pentru depunere:	14.11.16	Pretul estimativ:	10.500,00 RON
----------------------------------	----------	-------------------	---------------

---

Descriere: 1.Verificat, reparat generator electric tip Meccalte ECO 3-1S/2, 6/8 kW, 50/60 Hz, 115/230/400 V, 3000/3600 rpm - nu genereaza tensiunea 220 V/50 Hz. 2.Verificare, reglare generator electric in TPD si TDA, BETA SET - 7,7 kVA,3000/3600 rpm - 1 buc. Demontat echipamente, masurat, eliberat buletin masuratori, montat pe pozitie.

---