
Standalone online UPS for data center

I.D.: 28479275

Documente participante:

- 1.RENAM UPS Specifications v2.pdf
- 2.audit_7cf05224623c4023bfdd5fa1014f6a85.yaml

Data publicarii	28.05.18	Coduri CPV	31154000-0
-----------------	----------	------------	------------

Termenul limita pentru depunere:	04.05.18	Pretul estimativ:	35.000,00 MDL
----------------------------------	----------	-------------------	---------------

Descriere: Rated power at least 3 KW; Voltage input: 230 Vac single-phase; Output frequency: 50/60 Hz selectable; Battery type: Maintenance-free sealed lead acid; Operating temperature: 0 - 40 °C; Ability to monitor the system using SNMP protocol; Temperature sensor; Rack mount; Service engineer certified by the proposed brand; Experience on local market: at least 2 years
