



Reparatie centrala termica

I.D.: 57039366

Data publicarii	19.05.21	Coduri CPV	45259300-0
-----------------	----------	------------	------------

Termenul limita pentru depunere:	26.05.21	Pretul estimativ:	30.000,00 RON - 42.000,00 RON
----------------------------------	----------	-------------------	-------------------------------

Descriere: Reparatie sistem centrala termica industriala avand urmatoarele defectiuni constatate: - grup pompe 4KW nu functioneaza, -statie dedurizare defecta, -plutitor metalic 1" rezervor condens 2 bc defecte, -automat incarcare instalatie termica in presiune caleffi 3/4 defect - clapet sens 2.1/2" bronz -2bc necesita inlocuire -vas expansiune 200 litri membrana cauciuc natural presiune maxima 10 bari-defect -fitingaraie(teava metal,robineti ,mufe,reductii,etc)se vor lua in calcul -manopera interventie(montat-demontat)
